



CORP. STOP	TYPE 1 & 2	TYPE 3 & 4
FORD	F1100G	F1000G
MUELLER	H15024	H15006

NOTES:

1. TYPE 1-INSTALL ANODE AS SHOWN IN STANDARD DETAIL W-15.
2. TYPES 1 & 2-WRAP CORPORATION STOP AND 5' OF COPPER TUBING WITH 10 MIL PVC TAPE (1/2" LAPPED).
3. TYPE 1-IF WATER MAIN IS COATED, REPLACE COATING ON MAIN AND COAT WELD-ON SERVICE SADDLE AND INSULATING BUSHING WITH 1/4" MIN. COATING OF SAME MATERIAL (OR 10 MIL PVC TAPE)
4. TYPE 2- IF MAIN IS POLYWRAPPED, REPAIR AND EXTEND POLYWRAP TO COVER CORPORATION STOP.
5. FOR WATER METER INSTALLATION SEE STANDARD DETAIL W-2.
6. ALL BRASS CORPS FOR BRASS SADDLES SHALL HAVE CC THREADS (SADDLES AND CORPS)

SERVICE CONNECTION SCHEDULE					
SERVICE SIZE	WATER MAIN MATERIAL				
	STEEL	D.I.P.	A.C.P.	R.P.M.	P.V.C.
3/4"	TYPE 1	TYPE 2	TYPE 3	TYPE 3	TYPE 4
1"	"	"	"	"	"
1- 1/2"	"	"	"	"	"
2"	"	"	"	"	"

APPROVED BY

W. H. K.

DATE

4/2/92

**CONNECTION TYPES FOR
3/4" - 2" SERVICE TAPS**

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.

W-1